

Know your No Go Zones when working with scaffolds.

If the worksite is near overhead electrical power lines, before erecting scaffolding, you must follow the relevant No Go Zone safety procedures:

- No work is to commence until the presence, location, type and operating voltage of all overhead cables near the worksite has been positively determined by a competent person.
- A Job Safety Analysis (JSA) must be developed for the scope of work and all persons performing the work should understand the JSA.
- If any scaffolding to be erected near overhead electrical power lines may breach the No Go Zone, you must obtain written permission from the electricity company.
- If you cannot comply with the No Go Zone safety procedures once the scaffold is erected, then NO work shall be undertaken without permission from the electricity company.

Further information and checklists for undertaking work near overhead or underground assets are available at www.ocei.vic.gov.au/industry/ngzone.html, www.ogs.vic.gov.au and www.workcover.vic.gov.au

CONTACT NUMBERS

Agility (AGL)	131 626
Alinta Network Services	132 099
CitiPower	131 280
Powercor Australia	132 206
TXU Networks	131 799
SPI PowerNet	03 8635 7333
Alcoa Australia	03 5245 1740
Yarra Trams	03 9610 3394
Connex Trains	03 9619 2977
Optus Weekday Overhead Assets	1800 500 305
Underground Assets	1800 505 777
Optus Weekend	131 344 for all assets
TELSTRA	132 203 Option 3
WorkSafe Victoria	1800 136 089



WORKSAFE VICTORIA

NO GO ZONES FOR OVERHEAD ELECTRICAL POWER LINES

Special provisions for scaffolds


JULY 2004



Will you be erecting scaffolding near overhead power lines?

If the answer is “yes”, you need to be aware of special provisions for scaffolding built near overhead power lines.

Details of these special conditions are available from your electricity distribution company, SPI PowerNet, the Office of the Chief Electrical Inspector or WorkSafe Victoria or by visiting: www.workcover.vic.gov.au/dir090/vwa/home.nsf/pages/nogozone
OR www.ocei.vic.gov.au/industry/ngzone.html



VICTORIAN WORKCOVER AUTHORITY
WorkSafe Victoria offers a complete range of health and Safety services.

- Emergency Response
- Advice, information and education
- Inspections and audits
- Licensing and certification
- Publications

WORKSAFE VICTORIA CONTACTS

Head Office
Victorian WorkCover Authority
24th Floor
222 Exhibition Street
Melbourne Victoria 3000
GPO Box 4306
Melbourne Victoria 3001
Phone 9641 1555
Fax 9641 1222
Toll-free 1800 136 089

LOCAL OFFICES

Ballarat 5338 4444
Bendigo 5443 8866
Dandenong 8792 9000
Geelong 5226 1200
Melbourne
(628 Bourke Street) 9941 0558
Mildura 5021 4001
Mulgrave 9565 9444
Preston 9485 4555
Shepparton 5831 8260
Traralgon 5174 8900
Wangaratta 5721 8588
Warrnambool 5562 5600

PUBLICATIONS

Phone 9641 1333
Fax 9641 1330

WEBSITE

www.workcover.vic.gov.au

EMAIL

info@workcover.vic.gov.au

VICTORIAN WORKCOVER ADVISORY SERVICE

24th Floor
222 Exhibition Street
Melbourne Victoria 3000
Phone 9641 1444
Fax 9641 1353
Toll-free 1800 136 089

EMAIL

advisory_service@workcover.vic.gov.au

WorkSafe Victoria is a division of the Victorian WorkCover Authority

VWA653/01/06.04

